

SAFETY AND BUILDINGS DIVISION Plumbing Product Review P.O. Box 2658 Madison, Wisconsin 53701-2658

Jim Doyle, Governor Mary P. Burke, Secretary

November 21, 2005

BLACK SWAN MFG.CO. JEFFREY LICHTEN 4540 W THOMAS ST CHICAGO IL 60651

Re: Description: SOLVENT CEMENT Manufacturer: BLACK SWAN MFG.CO.

Product Name: ALL WEATHER PVC CEMENT (CLEAR) MEDIUM BODIED

Model Number(s): 7070, 7075 AND 7076

Product File No: 20040512

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.40 (14)(b) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of November 2010.

This alternate approval is contingent upon compliance with the following stipulation(s):

• This product may be used on PVC gravity flow DWV pipe without primer.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE Plumbing Product Reviewer phone: 608-266-6742

fax: 608-267-9566

e-mail: mike.beckwith@wi.gov

SBD-10564-E (N.10/97) File Ref: 04051201.DOC